
Plan Review Summary

Building Information

Project Name:	CODA-GTRI 8th Floor Expansion-Fire Suppression	Floor/Room #:	8th Floor
Building #:	207	Department:	GTRI
Occupancy Type:	Business	Budget:	\$2M
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Chris Sanders
Architect/Engineer of Record:	Kara Thomas
Construction Manager:	Austin Lintault
Aim Project Number:	0425-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/19/2021
Disposition:	Approved	Date Completed:	4/21/2021

Status Statement

Note: Fire Sprinkler relocations/additions

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System: 2021-FS-087
-