

Plan Review Summary

Building Information

Project Name:	Summer 2021 Interior Building Refresh	Floor/Room #:	ALL floors
Building #:	011	Department:	Housing
Occupancy Type:	Dormitory	Budget:	\$250,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Wendel
Construction Manager:	Spencer Sheffield
Aim Project Number:	0107-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/3/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/14/2021

Status Statement

Note: Residential Range/Hood Fire Suppression

Review Comments:

1. Fire Suppression System shall be integrated into the building's fire alarm system.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Fire Suppression System: 2021-FS-137