
Plan Review Summary

Building Information

Project Name:	Weber 1 Fire Suppression-Weber SST1	Floor/Room #:	
Building #:	084	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$300,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Kyle Epstein
Construction Manager:	Mark Wood
Aim Project Number:	0204-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	2/18/2021
Disposition:	Declined	Date Completed:	2/24/2021

Status Statement

Note: Fire Sprinkler Piping Installation for future use

Review Comments:

1. Sheet T-1: Project description indicate fire sprinkler piping installation and emergency generator installation. Please submit these as two separate permits.
2. Sheet C-3: Please show the fire sprinkler piping going into the building. It does not appear to be on the civil plans.
3. Please provide the pipe size that will be installed inside the building, as well as the type.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Permits Required:

1. Construction / Interior Renovation
 2. Fire Suppression System
-