

---

## Plan Review Summary

---

### Building Information

Project Name:	Dr. Carr Lab Fit-Up- Weber SST1	Floor/Room #:	216, 217
Building #:	084	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$700,000.00
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Kyle Epstein
Construction Manager:	Mark Wood
Aim Project Number:	0202-2020

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	2/18/2021
Disposition:	Declined	Date Completed:	3/29/2021

---

### Status Statement

Note: New lab build-out; NFPA 45 applies

### Review Comments:

1. EHS comments per Ryan Lisk: 5 gallon quantities of Isopropyl Alcohol will be used and is not captured in the chemical inventory list; also sulfuric acid will be used and is not captured in the chemical inventory list.
2. In regards to above comment, flammable liquid storage cabinet and acid storage will be required.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Permits Required:

1. Construction / Interior Renovation
  2. Fire Suppression System
  3. Fire Alarm
-