
Plan Review Summary

Building Information

Project Name:	Peter Yunker Lab Fit Up-Cherry Emerson	Floor/Room #:	2nd Floor/#230 & 232
Building #:	066	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$588,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	HERA
Construction Manager:	Fenella Bryant
Aim Project Number:	0360-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/4/2021
Disposition:	Declined	Date Completed:	3/29/2021

Status Statement

Note: New Lab build-out; NFPA 45 applies

Review Comments:

1. G-003: please include all gases in the chemical inventory list.
2. Please provide the location of the flammable liquids cabinet.
3. Has the demolition already occurred? Verify asbestos survey status for fixtures to be removed.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-