
Plan Review Summary

Building Information

Project Name:	CODA-GTRI 8th Floor Expansion-Fire Alarm	Floor/Room #:	8th South Floor
Building #:	207	Department:	GTRI
Occupancy Type:	Business	Budget:	\$2M
Construction Type:	IB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Chris Sanders
Architect/Engineer of Record:	Kara Thomas
Construction Manager:	Austin Lintault
Aim Project Number:	0425-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/19/2021
Disposition:	Declined	Date Completed:	4/27/2021

Status Statement

Note: Fire alarm detection; smoke/heat detectors

Review Comments:

1. Please provide smoke detectors spaced accordingly in the corridor throughout the GT space in accordance with GT Yellow book standards.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

1. Fire Alarm
-