
Plan Review Summary

Building Information

Project Name:	Russ Chandler Baseball Renovation- Temporary Stairs	Floor/Room #:	Temporary Stairs
Building #:	168	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$10M
Construction Type:	IIIB	Type of Review:	Temporary Structure

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Cheung Li Wang
Construction Manager:	Jackie Avello
Aim Project Number:	2020-0359

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/9/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/10/2021

Status Statement

Note: Temporary Stairs

Review Comments:

1. Shall be anchored to the top section to the building as well

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction: 2021-TS-027
-