

Plan Review Summary

Building Information

Project Name:	Harris Residence Hall Re-Roof	Floor/Room #:	
Building #:	011	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$400,000.00
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Make 3 Architecture/Planning/Design
Construction Manager:	Spencer Sheffield
Aim Project Number:	0403-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/29/2020
Disposition:	WITHDRAWN PER PM	Date Completed:	1/30/2020

Status Statement

Note: Reroofing

Review Comments:

1. Provide dumpster location
2. Provide safety documentation
3. Follow hot work policy
4. No generators on the roof

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. **Fire Safety Office Project Kick-Off Meeting**
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction 2020-CP-027 WITHDRAWN PER PM 08/12/2020